

**Reprezentanta
Opel Di-Bas**

A4 Scurgeri minore la rezervorul de Benzina T2A si incendiu_Flash Fire



		ID_Eveniment	A4	
		Instalatie	Rezervor T2A	
		Tip_Eveniment	Flash Fire	
		Substanta_implicata	Benzina	
		Localitate	Ploiesti	
		Frecventa	$2 \cdot 10^{-5}$	an ⁻¹
	Mortalitate ridicata	Zona_I	12	m
	Prag de mortalitate	Zona_II	36	m
	Vătămări ireversibile	Zona_III	121	m
	Vătămări reversibile	Zona_IV	219	m

Scale: 1:5,000

Esri Romania, Esri, HERE, Garmin, GeoTechnologies, Inc, METI/NASA, USGS, Maxar