

**Reprezentanta  
Opel Di-Bas**

## C2 Scurgeri minore la o cisterna Auto cu Benzina si incendiu\_ Flash Fire



		ID_Eveniment	C2	
		Instalatie	Rampa Auto	
		Tip_Eveniment	Flash Fire	
		Substanta_implicata	Benzina	
		Localitate	Ploiesti	
		Frecventa	$2 \times 10^{-5}$	an <sup>-1</sup>
	Mortalitate ridicata	Zona_I	10	m
	Prag de mortalitate	Zona_II	31	m
	Vătămări ireversibile	Zona_III	104	m
	Vătămări reversibile	Zona_IV	168	m

**Scale: 1:5,000**

Esri Romania, Esri, HERE, Garmin, GeoTechnologies, Inc, METI/NASA, USGS, Maxar