

B2 Scurgeri minore la o cisterna CF cu Benzina si incendiu _ Flash Fire



		ID_Eveniment	B2	
		Instalatie	Rampa CF	
		Tip_Eveniment	Flash Fire	
		Substanta_implicata	Benzina	
		Localitate	Ploiesti	
		Frecventa	$2 \cdot 10^{-5}$	an ⁻¹
	Mortalitate ridicata	Zona_I	10	m
	Prag de mortalitate	Zona_II	31	m
	Vătămări ireversibile	Zona_III	104	m
	Vătămări reversibile	Zona_IV	168	m

Scale: 1:5,000

0 170 340 680 Meters

Isover

Esri Romania, Esri, HERE, Garmin, GeoTechnologies, Inc, METI/NASA, USGS, Maxar

Strada Mih