


#### LEGENDA:

	Conducte tur retur, pentru agent termic din Cupru, montate aparent
	VCE pard, 1/2" Qi=4,72kW (45/40°C) Qr=4,47kW(7/12°C)
	Radiator din otel, tip panou, complet echipat cu robinet de aerisire, robinet coltar tur/retur si senzor termostatic.
	22-tip radiator(grosimea) : 2 randuri aripioare; -840W : puterea termica a radiatorului (la temperatura agent termic tur/retur (45/40°C) -racord: 1/2" -lungime: 1200 mm -inaltime: 600 mm



VERIFICATOR / EXPERT	NUME	SEMNATURA	CERINTA	REFERAT / EXPERTIZA NR. / DATA
Proiectant general: <b>S.C. HAUSPLAN PROJEKT SRL</b> Str. Stefan Greceanu, nr. 3, Ploiesti, jud Prahova	Proiectant instalatii: <b>MJK INSTAL S.R.L.</b> CUI:36904269 PITESTI-ARGES		Beneficiar MUNICIPIUL PLOIESTI Titlu proiect: E.T. SI D.A.L.I. - REAMENAJARE IMOBIL DIN STRADA PREDEAL NR. 28 IN UNITATE DE INVATAMANT PRESCOLAR ADRESA: PLOIESTI, STR. PREDEAL, NR. 28	Pr.NR. 1017/2022  FAZA: D.A.L.I
PROIECTAT	ing. Alexandru Brebenel		SCARA 1:100	TITLU PLANSA : <b>INSTALATII TERMICE PLAN SUBSOL</b>
DESENAT	ing. Alexandru Brebenel		10.2022	PLANSA IT-01