

Scenariul 8.B. Avarierea unui palet echivalent a de 1 m3 (950 Kg), posibil a genera explozia BLEVE a paletului BLEVE



	ID_Eveniment	Sc8B	
	Instalatie	Hala de depozitare	
	Tip_Eveniment	BLEVE	
	Substanta	Ethyl acetat	
	Localitate	Ploiesti	
	Frecventa	1.12E-07	an ⁻¹
<div></div>	Mortalitate ridicata	Raza fireball	
<div></div>	Prag de mortalitate	350 kJ/mp	
<div></div>	Vătămări ireversibile	200 kJ/mp	
<div></div>	Vătămări reversibile	125 kJ/mp	
	Zona_I	78	m
	Zona_II	107	m
	Zona_III	127	m
	Zona_IV	163	m

0 70 140 280 Meters

Scale: 1:5,000