


Sc8. Explozie BLEVE rezervor GPL skid\_BLEVE



ID_Evenime	Sc.8	an <sup>-1</sup>
Instalatie	Skid GPL	
Tip_Evenim	BLEVE	
Substanta	GPL	
Localitate	Ploiesti	
Frecventa	10 <sup>-7</sup>	
Zona_I	28	
Zona_II	65	
Zona_III	92	
Zona_IV	111	

	Mortalitate ridicata	Raza fireball
	Prag de mortalitate	350 kJ/mp
	Vătămări ireversibile	200 kJ/mp
	Vătămări reversibile	125 kJ/mp



Scale: 1:3,000